



CONCRETE SIDEWALK NOTES

LOCATION	t	AT DRIVEWAYS
RESIDENTIAL	4"	6"
COMMERCIAL	5"	7"

DESCRIPTION	cr
ADA RAMP	0"
DRIVEWAY	1"-1 5/8"
ODOT TYPE 6 CURB	6" OR MATCH EXISTING

1. PROVIDE A BROOM FINISH TO ALL EXPOSED SURFACES IN THE TRANSVERSE DIRECTION. DO NOT PLASTER THE CONCRETE.
2. CONCRETE SHALL BE ODOT CLASS 'C' (6 SACK) PORTLAND CEMENT CONCRETE.
3. SIDEWALK THICKNESS SHALL BE AS SHOWN IN TABLE. WITHIN DRIVEWAY LIMITS, SIDEWALKS SHALL BE TWO INCHES THICKER. SEE DRIVEWAY DETAILS.
4. PROVIDE A 1/4 INCH RADIUS EDGE ON ALL OUTSIDE EDGES AND JOINTS.
5. INSTALL 1/2 INCH EXPANSION JOINT FILLER BETWEEN THE WALK AND ANY FIXED STRUCTURE OR AGAINST CURB. USE 1 INCH EXPANSION JOINT FILLER AGAINST THE BACK OF CURB ON A RADIUS OF 250 FEET OR LESS.
6. CURE CONCRETE IN ACCORDANCE WITH ODOT 451.



**CITY OF ALLIANCE
ENGINEERING DEPARTMENT**
504 E. MAIN ST.
ALLIANCE, OH 44601
PHONE: (330) 823-5122 FAX: (330) 829-2236

INTEGRAL CURB & WALK; CURB & PAVEMENT

NOT TO SCALE
ENGSERV1 / E:/ DATA / ENGINEERING DOCUMENTS / STANDARD DRAWINGS / INTEGRAL CURB & WALK; CURB & PAVEMENT

APPROVED BY:

 PE, S.T.
VINCENT MUESER, P.E., S.I.T.
ALLIANCE CITY ENGINEER

**ALLIANCE RD-9
(1 OF 1)**

Revisions / Drawn By

10-31-19 / ANP
01-31-22 / ANP