



NOTES

1. BURY HYDRANT 4.5' DEEP
2. SOLID CONCRETE BLOCK TO BE USED UNDER ALL TEE'S, BENDS AND HYDRANT ELBOW.
3. No. 57 WASHED GRAVEL FILL AROUND HYDRANT DRAIN AND TO A DEPTH OF 2'-0".
4. SOLID CONCRETE BLOCK WITH OAK WEDGES. (BRACED AGAINST UNDISTURBED SOIL)
5. PUMPER NOZZLE FACING STREET.

ITEM DESCRIPTION

- | | |
|---|---|
| A | MUELLER HYDRANT, 3-WAY "CENTURION" MODEL |
| B | 6" M.J. GATE VALVE (OPENING TO THE RIGHT) |
| C | 12" ANCHOR COUPLING (F-1211) |
| D | STANDARD ANCHOR TEE |
| E | EAST-JORDAN #1570 CASTING |
| F | 8" SDR 35 RISER |

CITY OF ALLIANCE
ENGINEERING DEPARTMENT
 504 E. MAIN ST.
 ALLIANCE, OH 44601
 PHONE: (330) 823-5122 FAX: (330) 829-2236

HYDRANT DETAIL
 NOT TO SCALE
 ENGSERV1 / E:/ DATA / ENGINEERING DOCUMENTS / STANDARD DRAWINGS / W-4.DWG

APPROVED BY:

 VINCENT MUESER, P.E., S.I.T.
 ALLIANCE CITY ENGINEER

ALLIANCE W-4
(1 OF 1)

Revisions / Drawn By
01-31-22 / ANP